

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 05.06.2025

It is certified that an inspection team headed by Dr. Pardeep Yadav

(Name of Officers with designation) from P.H.C. Ladwa PHED

inspected the ST. MARY'S SCHOOL HISAR

(Name & Address of the school) on (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1566 dated 05. Jun. 2025

of DISTRICT WATER TESTING (PHED Lab) certified that the

LABORATORY HISAR
ST. MARY'S SCHOOL, HISAR (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :


OIC
PHC Ladwa

PARDEEP YADAV

OIC

To

ST MARY'S SCHOOL
6th mile stone, Tosham Road, HISAR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



O/o Civil Surgeon , Hisar

Mail-Id:- dhs.cshsr@hry.nic.in

Letter No. HSR/DHO/HI/2024/ 313

Dated: 18-12-2024


OFFICE OF CIVIL SURGEON HISAR

Hygienic and Sanitation certificate

Certified that the condition of the building of St. Mary's School, Tosham Road, Hisar with regards to the Sanitation and Hygienic condition is satisfactory for the one year w.e.f date of issuing.


Dy Civil Surgeon(Health)

For Civil Surgeon, Hisar



Memo No:- 1566

Date:- 05/06/2025

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : HSR/03075/6/2025 / Private Sender : ST MARYS SCHOOL Location : , 6TH KM STONE TOSHAM ROAD HISAR Sample Description : Drinking Water Latitude / Longitude : 75.749944 / 29.115573			Sample Details		Date & Time	
			Collected By		RAJBIR SINGH	
			Collection Date		04/06/2025 at 13:18	
			Received at lab		04/06/2025 at 15:15	
			Analysis Start Date		04/06/2025	
			Analysis End Date		05/06/2025	
			Sample Quantity		2 Ltr.	
Test Result (As Per BIS 10500 :2012)						
S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used	
1	Turbidity	0.32	1 NTU	5 NTU	APHA 24th Edition -2130 B	
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 2023	
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018	
4	Color	5	5 Hazen Units	15 Hazen Units	APHA 24th Edition -2120-B	
5	Total Dissolved Solids @ 180°C ± 2°C	35	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C	
6	Total Hardness as CaCo3	20	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C	
7	Calcium as Ca	4.008	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B	
8	Magnesium as Mg	2.43	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B	
9	Total Alkalinity	24	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B	
10	Chloride as Cl	22.68	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B	
11	Sulphate as So4	12	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO4-E	
12	Fluoride as F	0.018	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C	
13	Iron as Fe	0.01	1.0 mg/lit.	1.0 mg/lit.	USEPA / APHA 24th Edition - 3500 Fe-B	
14	Nitrate as No3	0.2	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO3 D	
15	pH @ 25°C	6.59	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B	

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED HISAR Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :

RAJEEV KUMAR, CHEMIST
DISTRICT WATER TESTING LABORATORY, HISAR
email:-chemist.hisar@phedharyana.gov.in